

RFQ 1FY20 QUESTION(S)

RFQ 1FY20 Question 10:

1. Do we need to use galvanized materials or stainless steel materials for the kennel construction?? See attached sample pictures.
 - **Whichever is more durable.**
2. Typical side panels are 4' high of solid material (to prevent fence fighting and nose to nose dog interaction) with 2' of bars above it for a 74" finished height. Is this acceptable??
 - **4' is acceptable. 6' would be preferred.**
3. Do any of the kennels get top covers?
 - **Yes**
4. Do the inside kennels have built in food and water bowls?
 - **No**
5. What is the proposed floor slope for the slab under the kennels?
 - **1/2 inch per 10 feet**
6. As there are additional scopes added from 12/03/2019 can we expect a BID extension for one more week ?
 - **Written questions will be accepted until 9 December 2019 5:00pm EST.**