

RFQ 1FY20 K9 Training Center

RFQ K9 1FY20 Vendor Question 9

Should we assume the transformer is less than 100' from the building?

- Yes, it is within 100' of buildings