

RFQ 5FY19 Question 3:

1. Can you confirm the area beyond the 20' of new metal wall to be an OPEN structure with wall by others?
2. Is the roof panel to be a painted finish (standard colors) or Galvalume?
3. Does the standard metal wall panel (R-Panel) beyond the 20' require insulation? If so what R value?
 - The 20' is what we want to be able to incorporate the wall panels. The rest of the building can be the standard metal building siding. The panels will extend down each side 20' from the front then it will resume to the standard metal siding if that makes sense. Then for roof it will be Galvalume
 - Yes, they would need to be insulated using R13 insulation