

### RFQ 2FY20 Vendor Question 15

- Wind speed the 145 mph is specified under “door schedule” but see no reference for roof. However, no “exposure” is indicated. B or C? **145 mph wind rating for entire building including roof. If this doesn't answer your question, can you please elaborate?**
- Insulation- R-19 specified for walls but see no reference for roof. **R-30 for roof**
- Gutters and Downspouts- See no reference and assume that they will be required. Please verify. **Yes**
- Collateral loads- In absence of any specs we'll assume a standard 1 lb. psf load. Please verify. **Is this for concrete or metal building? Metal building will come with the specifications for metal building manufacturer.**
- The drawings are for 50' x 80' metal buildings without any parapet. The specs call for (2) buildings that are each 50' x 70' with parapet on high side and 2" ISP panels. Please verify. **50'x80'. We would like the parapet so it matches other buildings on the site.**