

### RFQ 2FY20 Vendor Question 3

1. We do not see any spec for the manufacture or type of product called out for the epoxy flooring. *We don't have a specific requirement. Please keep in mind it will have potentially biohazardous materials in there so the purpose is to have something that can be sprayed down and sanitized.*
2. Sheet A-1.4 Indoor Training calls for a Double Coat of epoxy. Again no product spec given. *See above response.*
3. Note 4 on sheet A1.4 Indoor training calls for the epoxy to cover the lower half of the walls and cove base. I am assuming this is to have an Integral Cove but does not state how high, 4, 6 inches. *The epoxy flooring is to go 6" up base of wall.*
4. How high up the walls is the epoxy coating to be installed. No spec. *The epoxy coating is to cover the base 6" of the wall.*
5. Sheet A1.4 Kennel appears to call for a flake floor. No spec. *please use granite seamless flooring or equal for flake flooring.*
6. Sheet A1.4 Kennel note #1 says all flooring to be per owner. Is the owner handling all the flooring on this job? *No, that means we will work with selected vendor to identify colors or other user-defined details of whatever flooring option is quoted by the Bidder.*