

RFQ 2FY20 Vendor Question 6

1. The specifications state both buildings to be approximately 50' wide x 70' long, the plans show the building to be 50' wide x 80' long. Go with the plans for our takeoff? **YES, THE BUILDING IS TO BE 50'-0" X 80'-0"**.
2. The specifications call for the wall panels to be a 2" thick insulated panel, however the architectural drawings show an R19 blanket insulation with no insulated panels indicated. Please clarify. **THE 2" KINGSPAN OPTIMO EXTERIOR WALL PANELS (OR SIMILAR) SHOULD BE USED FOR THE EXTERIOR SO THE BUILDINGS WILL MATCH OTHERS ON THE PROPERTY.**
3. The roof panel is undefined. Please indicate type, manufacturer, model, gage, and finish requirements. **ALL METAL BUILDING INCLUDE THE METAL ROOF AS PART OF THE BUILDING PACKAGE. FOR THE KENNEL BUILDING, PLEASE USE: MERCHANT + EVANS 2" ZIP-LOK STANDING SEAM PANEL ROOF 16" COVERAGE, 24 GAGE GALVANIZED COATED STEEL, SMOOTH TEXTURE FINISH. ALTERNATE ROOFING REQUIRES SUBMITTAL FOR APPROVAL.**